



ORDINANCE NO. 3612

AN ORDINANCE OF THE CITY OF FARMERS BRANCH, TEXAS, AMENDING THE CODE OF ORDINANCES BY AMENDING CHAPTER 22 "BUILDINGS AND BUILDING REGULATIONS" BY AMENDING ARTICLE VII.5 "FUEL GAS CODE" ADOPTING THE 2018 EDITION OF THE INTERNATIONAL FUEL GAS CODE WITH AMENDMENTS; PROVIDING A REPEALING CLAUSE; PROVIDING A SAVINGS CLAUSE; PROVIDING A SEVERABILITY CLAUSE; PROVIDING FOR A PENALTY OF FINE NOT TO EXCEED THE SUM OF TWO THOUSAND DOLLARS (\$2,000.00) FOR EACH OFFENSE; AND PROVIDING FOR AN EFFECTIVE DATE.

WHEREAS, the International Code Council (ICC) has developed a set of comprehensive and coordinated national model construction codes (known generally as the "International Codes"); and

WHEREAS, the City of Farmers Branch has been involved throughout the development process of the International Codes through participation with the North Texas Chapter of the International Code Council and through the regional review process by the Regional Codes Coordinating Committee of the North Central Texas Council of Governments (NCTCOG); and

WHEREAS, the creation of the 2018 editions of the International Codes by the ICC was in conjunction with the International Conference of Building Officials (ICBO), the organization whose codes the City of Farmers Branch has adopted since the 1970s; and

WHEREAS, the International Codes have been reviewed by the NCTCOG and City staff; and

WHEREAS, the City's building and construction codes are intended to be updated periodically, with the 2018 editions of the International Codes being the most current published building and construction codes for which local amendments have been developed; and

WHEREAS, the City Council of the City of Farmers Branch has determined that it is in the best interest of the citizens of the City of Farmers Branch to adopt the 2018 editions of the International Codes, as stated herein, as the minimum standards for the construction, use, occupancy and maintenance of buildings and structures within the City limits, as set forth herein, and to adopt local amendments to said codes in order to account for unique local practices and/or conditions relating to the design and construction of structures within the City;

NOW, THEREFORE, BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF FARMERS BRANCH, TEXAS, THAT:

SECTION 1. Chapter 22 “Buildings and Building Regulations” of the Code of Ordinances of the City of Farmers Branch, Texas, is amended by amending Article VII.5 “Fuel Gas Code” to read as follows:

ARTICLE VII.5. FUEL GAS CODE

Sec. 22-230. Adoption of International Fuel Gas Code; purpose.

The 2018 Edition of the *International Fuel Gas Code*, as published by the International Code Council and as amended pursuant to Sec. 22-231, is hereby adopted. Copies of the Fuel Gas Code are on file in the office of the city secretary for permanent record and inspection and are incorporated into this section as if fully set forth herein. The chief building official, or his authorized representative, is hereby authorized and directed to enforce all provisions of the Fuel Gas Code. For purposes of this Article, the phrase “Fuel Gas Code” means collectively (i) the 2018 Edition of the *International Fuel Code*, as published by the International Code Council and (ii) the local amendments adopted pursuant to Sec. 22-231.

Sec. 22-231. Local Amendments to International Fuel Gas Code.

For purposes of enforcement of the provisions of the Fuel Gas Code within the incorporated limits of the City, the following sections, paragraphs, and sentences of the 2018 Edition of the *International Fuel Gas Code* are hereby amended as follows:

Section 102.2 is amended by adding a paragraph titled “Exception” to read as follows:

Exception: Existing dwelling units shall comply with Section 621.2.

Section 102.8 is amended to read as follows:

102.8 Referenced codes and standards. The codes and standards referenced in this code shall be those that are listed in Chapter 8 and such codes, when specifically adopted, and standards shall be considered as part of the requirements of this code to the prescribed extent of each such reference. Where the differences occur between provisions of this code and the referenced standards, the provisions of this code shall be the minimum requirements. Whenever amendments have been adopted to the referenced codes and standards, each reference to said code and standard shall be considered to reference the amendments as well. Any reference to NFPA 70 or the ICC *Electrical Code* shall mean the Electrical Code as adopted.

Section 106.6.2 is amended to read as follows:

106.6.2 Fee schedule. The fees for all plumbing work shall be as adopted by ordinance and/or resolution of the City Council.

Section 106.6.3 is amended to read in its entirety as follows:

106.6.3 Fee Refunds. The code official shall establish a policy for authorizing the refunding of fees.

Section 109.1 is amended to read as follows:

109.1 Application for appeal. Any person shall have the right to appeal a decision of the code official to the board of appeals established by ordinance. The board shall be governed by the enabling ordinance.

109.1.1 Limitations of Authority. The board of appeals shall have no authority relative to interpretations of the administrative provisions of this code nor shall the board be empowered to waive requirements of this code.

Section 109.2 is amended to read as follows:

109.2 Appointment. The members of the Zoning Board of Adjustment of the City of Farmers Branch shall be appointed as the board of appeals.

Sections 109.2.5 through 109.7, inclusive, are deleted.

Section 306.3 is amended to read in its entirety as follows:

[M] 306.3 Appliances in attics. Attics containing appliances shall be provided ... *{intervening language unchanged}* ... side of the *appliance*. The clear *access* opening dimensions shall be a minimum of 20 inches by 30 inches (508 mm by 762 mm), or larger where such dimensions are not large enough to allow removal of the largest *appliance*. A walkway to an appliance shall be rated as a floor as approved by the building official. As a minimum, for *access* to the attic space, provide one of the following:

1. A permanent stair.
2. A pull down stair with a minimum 300 lb (136 kg) capacity.
3. An *access* door from an upper floor level.
4. *Access* Panel may be used in lieu of items 1, 2, and 3 with prior approval of the code official due to building conditions.

Exceptions:

1. The passageway and level service space are not required where the *appliance* is capable of being serviced and removed through the required opening.
2. Where the passageway is not less than ... (*remainder of section unchanged*).

Section 306.5 is amended to read as follows:

[M] 306.5 Equipment and appliances on roofs or elevated structures. Where *equipment* requiring *access* or appliances are located on an elevated structure or the roof of a building such that personnel will have to climb higher than 16 feet (4877 mm) above grade to access, a permanent interior or exterior means of access shall be provided. Exterior ladders providing roof *access* need not extend closer than 12 feet (2438 mm) to the finish grade or floor level below and shall extend to the *equipment* and appliances' level service space. Such *access* shall . . . *{intervening language unchanged}*. . . on roofs having a slope greater than four units vertical in 12 units horizontal (33-percent slope). . . *{remainder of section unchanged}*.

Section 306.5.1 is amended to read as follows:

[M] 306.5.1 Sloped roofs. Where appliances, *equipment*, fans or other components that require service are installed on a roof having a slope 3 units vertical in 12 units horizontal (25 percent slope) or greater and having an edge more than 30 inches (762 mm) above grade at such edge, a catwalk at least 16 inches in width with substantial cleats spaced not more than 16 inches apart shall be provided from the roof *access* to a level platform at the appliance. The level platform shall be provided on each side of the appliance to which *access* is required for service, repair or maintenance. The platform shall be not less than 30 inches (762 mm) in any dimension and shall be provided with guards. The guards shall extend not less than 42 inches (1067 mm) above the platform, shall be constructed so as to prevent the passage of a 21-inch-diameter (533 mm) sphere and shall comply with the loading requirements for guards specified in the *International Building Code*.

Section 401.5 is amended by adding the following language at the end of the section:

...Both ends of each section of medium pressure gas piping shall identify its operating gas pressure with an *approved* tag. The tags are to be composed of aluminum or stainless steel and the following wording shall be stamped into the tag:

"WARNING
1/2 to 5 psi gas pressure
Do Not Remove"

Section 404.12 is amended to read as follows:

404.12 Minimum burial depth. Underground piping systems shall be installed a minimum burial depth of 18 inches (458 mm) measured from the top of the pipe to surrounding finished grade.

Section 404.12.1 is deleted in its entirety.

Section 406.4 is amended to read as follows:

406.4 Test pressure measurement. Test pressure shall be measured with a manometer or with a pressure-measuring device designed and calibrated to read, record, or indicate a pressure loss caused by leakage during the pressure test period. The source of pressure shall be isolated before the pressure tests are made.

Section 406.4.1 is amended to read in its entirety as follows:

406.4.1 Test pressure. The test pressure to be used shall be no less than 3 psig (20 kPa gauge), or at the discretion of the Code Official, the piping and valves may be tested at a pressure of at least six (6) inches (152 mm) of mercury, measured with a manometer or slope gauge. For tests requiring a pressure of 3 psig, diaphragm gauges shall utilize a dial with a minimum diameter of three and one-half inches (3 ½"), a set hand, 1/10-pound incrementation and pressure range not to exceed 6 psi for tests requiring a pressure of 3 psig. For tests requiring a pressure of 10 psig, diaphragm gauges shall utilize a dial with a minimum diameter of three and one-half inches (3 ½"), a set hand, a minimum of 2/10 pound incrementation and a pressure range not to exceed 20 psi. For welded piping, and for piping carrying gas at pressures in excess of fourteen (14) inches water column pressure (3.48 kPa) (1/2 psi) and less than 200 inches of water column pressure (52.2 kPa) (7.5 psi), the test pressure shall not be less than ten (10) pounds per square inch (69.6 kPa). For piping carrying gas at a pressure that exceeds 200 inches of water column (52.2 kPa) (7.5 psi), the test pressure shall be not less than one and one-half times the proposed maximum working pressure. Diaphragm gauges used for testing must display a current calibration and be in good working condition. The appropriate test must be applied to the diaphragm gauge used for testing.

Section 409.1 is amended by adding Section 409.1.4 to read as follows:

409.1.4 Valves in CSST installations. Shutoff valves installed with corrugated stainless steel (CSST) piping systems shall be supported with an *approved* termination fitting, or equivalent support, suitable for the size of the valves, of adequate strength and quality, and located at intervals so as to prevent or damp out

excessive vibration but in no case greater than 12-inches from the center of the valve. Supports shall be installed so as not to interfere with the free expansion and contraction of the system's piping, fittings, and valves between anchors. All valves and supports shall be designed and installed so they will not be disengaged by movement of the supporting piping.

Section 410.1 is amended by adding the following sentence at the end of the section and a new paragraph titled "Exception" to read as follows:

Access to regulators shall comply with the requirements for *access* to appliances as specified in Section 306.

Exception: A passageway or level service space is not required when the regulator is capable of being serviced and removed through the required attic opening.

Section 621.2 is amended by adding a paragraph titled "Exception" to read as follows:

Exception: Existing *approved* unvented heaters may continue to be used in dwelling units, in accordance with the code provisions in effect when installed, when *approved* by the Building Official unless an unsafe condition is determined to exist as described in Section 108.7.

SECTION 2. That all provisions of the Ordinances of the City of Farmers Branch, Texas, in conflict with the provisions of this ordinance be, and the same are hereby, repealed, and all other provisions of the Ordinances of the City not in conflict with the provisions of this ordinance shall remain in full force and effect.

SECTION 3. An offense committed before the effective date of this ordinance is governed by prior law and the provisions of the Code of Ordinances, as amended, in effect when the offense was committed and the former law is continued in effect for this purpose.

SECTION 4. That should any word, sentence, paragraph, subdivision, clause, phrase or section of this ordinance, be adjudged or held to be void or unconstitutional, the same shall not affect the validity of the remaining portions of said ordinance, which shall remain in full force and effect.

SECTION 5. That any person violating any of the provisions or terms of this ordinance shall be subject to the same penalty as provided for in the Code of Ordinances of the City of Farmers Branch as heretofore amended and, upon conviction, shall be punished by a fine not to exceed the sum of Two Thousand Dollars (\$2,000.00).

SECTION 6. This Ordinance shall take effect on January 1, 2020, from and after its passage and the publication of the caption, as the law and charter in such case provide.

**DULY PASSED BY THE CITY COUNCIL OF THE CITY OF FARMERS BRANCH,
TEXAS, ON THE 12TH DAY OF NOVEMBER 2019.**

ATTEST:

Amy Piukana, City Secretary

APPROVED:

Robert C. Dye, Mayor

APPROVED AS TO FORM:

Peter G. Smith, City Attorney
(kbl:11/1/19:111920)