



ORDINANCE NO. 3610

AN ORDINANCE OF THE CITY OF FARMERS BRANCH, TEXAS, AMENDING THE CODE OF ORDINANCES BY AMENDING CHAPTER 22 "BUILDINGS AND BUILDING REGULATIONS", ARTICLE VII "PLUMBING STANDARDS" TO ADOPT THE 2018 EDITION OF THE INTERNATIONAL PLUMBING CODE WITH AMENDMENTS; PROVIDING A REPEALING CLAUSE; PROVIDING A SAVINGS CLAUSE; PROVIDING A SEVERABILITY CLAUSE; PROVIDING FOR A PENALTY OF FINE NOT TO EXCEED THE SUM OF TWO THOUSAND DOLLARS (\$2,000.00) FOR EACH OFFENSE; AND PROVIDING FOR AN EFFECTIVE DATE.

WHEREAS, the International Code Council (ICC) has developed a set of comprehensive and coordinated national model construction codes (known generally as the "International Codes"); and

WHEREAS, the City of Farmers Branch has been involved throughout the development process of the International Codes, through participation with the North Texas Chapter of the International Code Council and through the regional review process by the Regional Codes Coordinating Committee of the North Central Texas Council of Governments (NCTCOG); and

WHEREAS, the creation of the 2018 editions of the International Codes by the ICC was in conjunction with the International Conference of Building Officials (ICBO), the organization whose codes the City of Farmers Branch has adopted since the 1970s; and

WHEREAS, the International Codes have been reviewed by the NCTCOG and City staff; and

WHEREAS, the City's building and construction codes are intended to be updated periodically, with the 2018 editions of the International Codes being the most current published building and construction codes for which local amendments have been developed; and

WHEREAS, the City Council of the City of Farmers Branch has determined that it is in the best interest of the citizens of the City of Farmers Branch to adopt the 2018 editions of the International Codes, as stated herein, as the minimum standards for the construction, use, occupancy and maintenance of buildings and structures within the City limits, as set forth herein, and to adopt local amendments to said codes in order to account for unique local practices and/or conditions relating to the design and construction of structures within the City;

SECTION 1. Chapter 22 titled "Buildings and Building Regulations" of the Code of Ordinances of the City of Farmers Branch, Texas, is amended by amending Article VII "Plumbing Standards" to read as follows:

ARTICLE VII. PLUMBING STANDARDS

Sec. 22-226. Adoption of International Plumbing Code; purpose.

The 2018 Edition of the *International Plumbing Code*, as published by the International Code Council and as amended pursuant to Sec. 22-227, is hereby adopted. Copies of the Plumbing Code are on file in the office of the city secretary for permanent record and inspection and are incorporated into this section as if fully set forth herein. The chief building official, or his authorized representative, is hereby authorized and directed to enforce all provisions of the Plumbing Code. For purposes of this Article, the phrase "Plumbing Code" means collectively (i) the 2018 Edition of the *International Plumbing Code*, as published by the International Code Council and (ii) the local amendments adopted pursuant to Sec. 22-227

Sec. 22-227. Amendments to International Plumbing Code.

For purposes of enforcement of the provisions of the Plumbing Code within the incorporated limits of the City, the following sections, paragraphs, and sentences of the 2018 Edition of the *International Plumbing Code* are hereby amended as follows:

Table of Contents, Chapter 7, Section 713 is amended to read as follows:

713 Engineered Drainage Design 69

Section 102.8 is amended to read as follows:

102.8 Referenced codes and standards. The codes and standards referenced in this code shall be those that are listed in Chapter 15 and such codes, when specifically adopted, and standards shall be considered as part of the requirements of this code to the prescribed extent of each such reference. Where the differences occur between provisions of this code and the referenced standards, the provisions of this code shall be the minimum requirements. Whenever amendments have been adopted to the referenced codes and standards, each reference to said code and standard shall be considered to reference the amendments as well. Any reference to NFPA 70 or the ICC *Electrical Code* shall mean the Electrical Code as adopted

Sections 106.6.2 and 106.6.3 are amended to read as follows:

106.6.2 Fee schedule. The fees for all plumbing work shall be adopted by resolution or ordinance of the City Council.

106.6.3 Fee Refunds. The code official shall establish a policy for authorizing the refunding of fees.

Sections 109.1 and 109.2 shall be amended to read as follows:

109.1 Application for appeal. Any person shall have the right to appeal a decision of the code official to the board of appeals established by ordinance. The board shall be governed by the enabling ordinance.

109.1.1 Limitations of Authority. The board of appeals shall have no authority relative to interpretations of the administrative provisions of this code nor shall the board be empowered to waive requirements of this code.

109.2 Appointment. The members of the Zoning Board of Adjustment of the City of Farmers Branch shall be appointed as the board of appeals.

Sections 109.2.5 through 109.7 are deleted.

Section 305.1 is amended to read as follows:

305.1 Protection against contact. Metallic piping, except for cast iron, ductile iron and galvanized steel, shall not be placed in direct contact with steel framing members, concrete or cinder walls and floors or other masonry. Metallic piping shall not be placed in direct contact with corrosive soil. Where sheathing is used to prevent direct contact, the sheathing shall have a thickness of not less than 0.008 inch (8 mil) (0.203 mm) and the sheathing shall be made of approved material. Where sheathing protects piping that penetrates concrete or masonry walls or floors, the sheathing shall be installed in a manner that allows movement of the piping within the sheathing.

Section 305.4.1 is amended to read as follows:

305.4.1 Sewer depth. Building sewers shall be a minimum of 12 inches (304 mm) below grade.

Section 305.7 is amended to read as follows:

305.7 Protection of components of plumbing system. Components of a plumbing system installed within 3 feet along alleyways, driveways, parking garages or other locations in a manner in which they could be exposed to damage shall be recessed into the wall or otherwise protected in an *approved* manner.

Section 314.2.1 is amended to read as follows:

314.2.1 Condensate disposal. Condensate from all cooling coils and evaporators shall be conveyed from the drain pan outlet to an *approved* place of disposal. ... {intervening text unchanged} ... Condensate shall not discharge into a street, alley, sidewalk, rooftop, or other areas so as to cause a nuisance.

Section 409.2 is amended to read as follows:

409.2 Water connection. The water supply to a commercial dishwashing machine shall be protected against backflow by an air gap or backflow preventer in accordance with Section 608. *{remainder of section unchanged}*

Section 413.4 is amended to read as follows:

413.4 Required location for floor drains. Floor drains shall be installed in the following areas.

1. In public coin-operated laundries and in the central washing facilities of multiple family dwellings, the rooms containing automatic clothes washers shall be provided with floor drains located to readily drain the entire floor area. Such drains shall have a minimum outlet of not less than 3 inches (76 mm) in diameter.
2. Commercial kitchens. In lieu of floor drains in commercial kitchens, the code official may accept floor sinks.
3. Public restrooms.

Section 502.3 is amended to read as follows:

502.3 Water heaters installed in attics. Attics containing a water heater shall be provided *{intervening language unchanged}* side of the water heater. The clear access opening dimensions shall be a minimum of 20 inches by 30 inches (508 mm by 762 mm), or larger where such dimensions be not less than 20 inches by 30 inches (508mm by 762mm) where such dimensions are large enough to allow removal of the water heater. As a minimum, for access to the attic space, provide one of the following:

1. A permanent stair.
2. A pull down stair with a minimum 300 lb (136 kg) capacity.
3. An access door from an upper floor level.
4. Access Panel may be used in lieu of items 1, 2, and 3 with prior approval of the code official due to building conditions.

Exceptions:

1. The passageway and level service space are not required where the appliance is capable of being serviced and removed... *{remainder of section unchanged}*

Section 502 is amended by adding Section 502.6 to read as follows:

502.6 Water heaters above ground or floor. When the attic, roof, mezzanine or platform in which a water heater is installed is more than eight (8) feet (2438 mm) above the ground or floor level, it shall be made accessible by a stairway or permanent ladder fastened to the building.

Exception: A max 10 gallon water heater (or larger with approval) capable of being accessed through a lay-in ceiling not more than ten (10) feet (3048 mm) above the ground or floor level which may be reached with a portable ladder.

Section 504.6 is amended to read as follows:

504.6 Requirements for discharge piping. The discharge piping serving a pressure relief valve, temperature relief valve or combination thereof shall:

1. Not be directly connected to the drainage system.
2. Discharge through an air gap.
3. Not be smaller than the diameter of the outlet of the valve served and shall discharge full size to the air gap.
4. Serve a single relief device and shall not connect to piping serving any other relief device or equipment.

Exception: Multiple relief devices may be installed to a single T & P discharge piping system when *approved* by the administrative authority and permitted by the manufactures installation instructions and installed with those instructions.

5. Discharge to an approved location or to the outdoors.
6. Discharge in a manner that does not cause personal injury or structural damage.
7. Discharge to a termination point that is readily observable by the building occupants.
8. Not be trapped.
9. Be installed so as to flow by gravity.

10. Terminate not more than 6 inches and not less than two times the discharge pipe diameter above the floor or flood level rim of the waste receptor.
11. Not have a threaded connection at the end of such piping.
12. Not have valves or tee fittings.
13. Be constructed of those materials listed in Section 605.4 or materials tested, rated and *approved* for such use in accordance with ASME A112.4.1.
14. Be one nominal size larger than the size of the relief valve outlet, where the relief valve discharge piping is installed with insert fittings. The outlet end of such tubing shall be fastened in place.

Section 504.7.1 is amended to read as follows:

504.7.1 Pan size and drain: The pan shall be not less than 1 1/2 inches (38 mm) in depth and shall be of sufficient size and shape to receive all dripping or condensate from the tank or water heater. The pan shall be drained by an indirect waste pipe having a diameter of not less than 3/4 inch (19 mm). Piping for safety pan drains shall be of those materials listed in Table 605.4. Multiple pan drains may terminate to a single discharge piping system when *approved* by the administrative authority and permitted by the manufactures installation instructions and installed with those instructions.

Section 608.1 is amended to read as follows:

608.1 General. A potable water supply system shall be designed, installed and maintained in such a manner so as to prevent contamination from non-potable liquids, solids or gases being introduced into the potable water supply through cross-connections or any other piping connections to the system. Backflow preventer applications shall conform to applicable local regulations, Table 608.1, and as specifically stated in Sections 608.2 through 608.16.10.

Section 608.17.5 is amended to read as follows:

608.17.5 Connections to lawn irrigation systems. The potable water supply to lawn irrigation systems shall be protected against backflow by an atmospheric-type vacuum breaker, a pressure-type vacuum breaker, a double-check assembly or a reduced pressure principle backflow preventer. A valve shall not be installed downstream from an atmospheric vacuum breaker. Where chemicals are introduced into the system, the potable water supply shall be protected against backflow by a reduced pressure principle backflow preventer.

Section 608.18 is amended to read as follows:

608.18 Protection of individual water supplies. An individual water supply shall be located and constructed so as to be safeguarded against contamination in accordance with applicable local regulations. Installation shall be in accordance with Sections 608.18.1 through 608.18.8.

Section 703.6 is deleted.

Section 704 is amended by adding Section 704.5 to read as follows:

704.5 Single stack fittings. Single stack fittings with internal baffle, PVC schedule 40 or cast iron single stack shall be designed by a registered engineer and comply to a national recognized standard.

Section 712 is amended by adding Section 712.5 to read as follows:

712.5 Dual Pump System. All sumps shall be automatically discharged and, when in any “public use” occupancy where the sump serves more than 10 fixture units, shall be provided with dual pumps or ejectors arranged to function independently in case of overload or mechanical failure. For storm drainage sumps and pumping systems, see Section 1113.

Section 713 is amended by changing the title caption to read “ENGINEERED DRAINAGE DESIGN”

Section 713.1 is amended to read as follows:

713.1 Design of drainage system. The sizing, design and layout of the drainage system shall be designed by registered professional engineer using *approved* design methods.

Section 803 is amended by adding Section 803.3 to read as follows:

803.3 Special waste pipe, fittings, and components. Pipes, fittings, and components receiving or intended to receive the discharge of any fixture into which acid or corrosive chemicals are placed shall be constructed of CPVC, high silicone iron, PP, PVDF, chemical resistant glass, or glazed ceramic materials.

Section 903.1 is amended to read as follows:

903.1 Roof extension. Open vent pipes that extend through a roof shall terminate not less than six (6) inches (152 mm) above the roof. Where a roof is to be used for assembly or as a promenade, observation deck, sunbathing deck or similar purposes, open vent pipes shall terminate not less than 7 feet (2134 mm) above the roof.

Section 918.8 is amended to read as follows:

918.8 Where permitted. Individual, branch and circuit vents shall be permitted to terminate with a connection to an individual or branch-type air admittance valve in accordance with Section 918.3.1. Stack vents and vent stacks shall be permitted to terminate to stack-type air admittance valves in accordance with Section 918.3.2. Air admittance valves shall only be installed with the prior approval of the building official.

Section 1106.1 is amended to read as follows:

1106.1 General. The size of the vertical conductors and leaders, building storm drains, building storm sewers, and any horizontal branches of such drains or sewers shall be based on six (6) inches per hour rainfall rate.

Section 1108.3 is amended to read as follows:

1108.3 Sizing of secondary drains. Secondary (emergency) roof drain systems shall be sized in accordance with Section 1106. Scuppers shall be sized to prevent the depth of ponding water from exceeding that for which the roof was designed as determined by Section 1101.7. Scuppers shall not have an opening dimension of less than 4 inches (102 mm). The flow through the primary system shall not be considered when sizing the secondary roof drain system.

Section 1109 is deleted.

Section 1202.1 is amended by deleting Paragraph1 and 2 under “Exceptions”.

SECTION 2. That all provisions of the Ordinances of the City of Farmers Branch, Texas, in conflict with the provisions of this ordinance be, and the same are hereby, repealed, and all other provisions of the Ordinances of the City not in conflict with the provisions of this ordinance shall remain in full force and effect.

SECTION 3. An offense committed before the effective date of this ordinance is governed by prior law and the provisions of the Code of Ordinances, as amended, in effect when the offense was committed and the former law is continued in effect for this purpose.

SECTION 4. That should any word, sentence, paragraph, subdivision, clause, phrase or section of this ordinance, be adjudged or held to be void or unconstitutional, the same shall not affect the validity of the remaining portions of said ordinance, which shall remain in full force and effect.

SECTION 5. That any person violating any of the provisions or terms of this ordinance shall be subject to the same penalty as provided for in the Code of Ordinances of the City of Farmers Branch as heretofore amended and, upon conviction, shall be punished by a fine not to exceed the sum of Two Thousand Dollars (\$2,000.00).

SECTION 6. This Ordinance shall take effect January 1, 2020. from and after its passage and the publication of the caption, as the law and charter in such case provide.

DULY PASSED BY THE CITY COUNCIL OF THE CITY OF FARMERS BRANCH, TEXAS, ON THE 12TH DAY OF NOVEMBER 2019.

ATTEST:

APPROVED:

Amy Piukana, City Secretary

Robert C. Dye, Mayor

APPROVED AS TO FORM:

Peter G. Smith, City Attorney
(kbl:11/1/2019:111912)