

City of Farmers Branch

Farmers Branch City Hall 13000 Wm Dodson Pkwy Farmers Branch, Texas 75234

Legislation Details (With Text)

File #: R2017-030 **Version**: 2

Type: Resolution Status: Consent Agenda

File created: 2/9/2017 In control: City Council

On agenda: 2/21/2017 Final action:

Title: Consider approving Resolution No. 2017-030 authorizing the City Manager to purchase Uninterrupted

Power Supply (UPS) systems and implementation services for the City Hall data center and the Emergency Operations Center in an amount totaling \$142,079 from Anixter, Inc.; and take appropriate

action.

Sponsors:

Indexes:

Code sections:

Attachments: 1. FB Res 2017-030, 2. City Hall Data Ctr UPS Quote 01459, 3. Fire 3/EOC UPS Quote 01468

Date Ver. Action By Action Result

Consider approving Resolution No. 2017-030 authorizing the City Manager to purchase Uninterrupted Power Supply (UPS) systems and implementation services for the City Hall data center and the Emergency Operations Center in an amount totaling \$142,079 from Anixter, Inc.; and take appropriate action.

BACKGROUND:

In order to ensure the operation of our critical technology infrastructure during a power outage or power surge, the City has a need to procure two (2) uninterruptible power supply (UPS) systems. One of the systems, which will consist of two physical units, would replace the existing UPS in the City Hall data center and the other would be a new implementation of a single system at the Emergency Operations Center, located in the Fire Administration building.

DISCUSSION:

A UPS system is a piece of critical infrastructure in any data center and offers a backup power supply in the event of a power surge or loss. Its most important function, however, is to offer protection for sensitive equipment contained in the data center in the event of a power surge or outage, and to prevent a loss of data if power is disrupted. In the event that the City experiences a loss of power, the UPS would provide emergency power that would keep our critical information systems up and running until the building generator begins operating.

<u>City Hall Data Center</u>: The City currently has a 10-year-old Liebert UPS system installed in the City Hall data center, which is used to provide a backup power supply to the mission critical server, data storage, telephony and network infrastructure.

This existing UPS system has experienced several significant malfunctions over the past year and a half, which is a major concern. Additionally, the current system uses antiquated technology and by design, has a single point of failure with no redundant components built in. These issues, along with the increasing demands and

File #: R2017-030, Version: 2

dependency on a UPS system necessitates the purchase of a replacement solution.

Emergency Operations Center: The Emergency Operations Center was recently relocated to the Fire Administration building, which does not currently have a UPS system in place. By not having a UPS system serving the EOC, it puts the operation at risk of experiencing a total loss of power during a critical EOC activation. Loss of power at this location would impact critical pieces of the operation, including the telephones, data network, computers, radios, etc.

The City of Farmers Branch requested vendor quotations utilizing the State of Texas Department of Information Resources contract pricing for data communications & networking equipment and related services. City Administration evaluated the quotations as to meeting specifications and desires to award the purchase of the UPS systems and implementation services to Anixter, Inc.

The UPS replacement project and associated funding was approved and included in the FY 16-17 budget.

RECOMMENDATION:

City Administration recommends approving Resolution No. 2017-030 authorizing the City Manager to purchase uninterrupted power supply (UPS) systems and implementation services for the City Hall data center and the Emergency Operations Center from Anixter, Inc. using the using the State of Texas catalog purchasing procedures, in an amount of \$142,079.

POSSIBLE COUNCIL ACTION:

- 1. I move to approve Resolution No. 2017-030 authorizing the City Manager to purchase uninterrupted power supply (UPS) systems and implementation services for the City Hall data center and the Emergency Operations Center from Anixter, Inc., in the amount of \$142,079.
- 2. Motion to deny Resolution No. 2017-030 authorizing the City Manager to purchase uninterrupted power supply (UPS) systems and implementation services for the City Hall data center and the Emergency Operations Center from Anixter, Inc., in the amount of \$142,079.
- 3. Motion to modify Resolution No. 2017-030 to meet the needs of the Council.
- 4. Motion to table the issue for further study or take no action.

ATTACHMENTS:

- 1. Council Resolution 2017-030
- 2. Quote City Hall Data Center UPS
- 3. Quote Fire Station 3/EOC UPS